

## Attachment I - Lead in Water Sample Results Summary

School Name: **Seventh Avenue Elementary School**

Outlet Code	Sample ID	Location/Description	Result (ppb)	Above AL?
1	38-1230-S01	Room 100; water fountain	4.16	No
2	38-1230-S02	Room 100; sink (left)	37.3	Yes
3	38-1230-S03	Room 100; sink (right)	42.1	Yes
4	38-1230-S04	Teachers Lounge; sink	5.46	No
5	38-1230-S05	MPR; water fountain	ND	No
6	38-1230-S06	MPR girls restroom; sink (2nd)	2.32	No
7	38-1230-S07	MPR boys restroom; sink (middle)	2.67	No
8	38-1230-S08	Room 118; small sink	ND	No
9	38-1230-S09	Hall near Room 120; water fountain	ND	No
10	38-1230-S10	Hall near Main Entrance; water fountain	2.56	No
11	38-1230-S11	Hall near Room 108; water fountain	ND	No
12	38-1230-S12	Boys restroom by Room 108; sink (middle)	3.5	No
13	38-1230-S13	Hall @ Girls restroom at end of hall; WF	ND	No
14	38-1230-S14	Girls restroom at end of hall; sink (2nd)	1.19	No
15	38-1230-S15	Top floor; water fountain	ND	No

Action Level (AL) ≥15.5 parts per billion (ppb)

